


NOTES:

- 1) HOISTWAY DIMENSIONS ARE MINIMUM CLEAR INSIDE DIMENSIONS.
- 2) FOR SEISMIC ZONES 2 AND UP, ADD 4" TO HOISTWAY WIDTH.
- 3) THIS CAR IS NOT 24"x84" GURNEY COMPLIANT.

HOISTWAY PLAN

OVERHEAD MACHINE DETAIL

TRACTION MRL:
FRAME BLDG SUPPORTED
2500 LB SSSO FRONT & REAR

NOT FOR CONSTRUCTION



ALLIANCE
ELEVATOR SOLUTIONS

335 NOVA DR.
GREENCASTLE, PA 17225

N.T.S.

1 OF 3

2023



NOTES:

- 1) HOISTWAY DIMENSIONS ARE MINIMUM CLEAR INSIDE DIMENSIONS.
- 2) FOR SEISMIC ZONES 2 AND UP, ADD 4" TO HOISTWAY WIDTH.
- 3) THIS CAR IS NOT 24"x84" GURNEY COMPLIANT.

HOISTWAY PLAN

OVERHEAD MACHINE DETAIL

TRACTION MRL:
FRAME BLDG SUPPORTED
2500 LB SSC0 FRONT & REAR

NOT FOR CONSTRUCTION

ALLIANCE
ELEVATOR SOLUTIONS



335 NOVA DR.
GREENCASTLE, PA 17225

N.T.S.

2 OF 3

2023

WHEN NO FULL BODY ENTRY INTO
OVERHEAD, GOVERNOR AND MACHINE
BREAK REQUIRE 24" x 24" ACCESS DOOR



CONTROLLER ROOM

BY DEFAULT CONTROLLER ROOM
IS LOCATED ON THE TOP LANDING
ADJACENT TO THE HOISTWAY

PIT & OVERHEAD BASED ON CAR SPEED AND CAPACITY

SPEED (FPM)	PIT	CAPACITY (LB)			
		2100	2500	3000	3500
100	5'-0"	14'-5"	14'-5"	14'-9"	14'-9"
150	5'-0"	14'-5"	14'-5"	14'-9"	14'-9"
200	5'-0"	14'-9"	14'-9"	14'-10"	14'-10"
250	5'-6"	14'-10"	14'-10"	14'-11"	14'-11"
300	5'-6"	14'-11"	14'-11"	15'-0"	15'-0"
350	5'-6"	15'-5"	15'-5"	15'-6"	15'-6"

NOTE: OIL BUFFERS REQUIRED FOR CAR
SPEED ABOVE 200 FPM. SPRING BUFFERS
MAY BE USED FOR 200 FPM AND BELOW.

SECTION "A"

NOT FOR CONSTRUCTION

ALLIANCE
ELEVATOR SOLUTIONS

335 NOVA DR.
GREENCASTLE, PA 17225

N.T.S.

3 OF 3

2023